## **Clevertest Plus**



Clevertest products must be "activated" before self-test functionality will operate. Refer to supplementary operation guide supplied with the Product or linked via QR code on packaging for details.

After Power ON, the Status LED on a Clevertest Plus enabled fitting will display a rapid Green or Red flashing for a period up to 2 minutes.

To register the fitting into Clevertest Plus app see supplementary guide.

# **Zoneworks, HIVE and DATA Monitored Options**

Fittings with part numbers -ZW, -HVG, -DATA are fitted with Zoneworks communications modules (nodes). These fittings are monitored using either Powerline Carrier Technology that utilize the power cable to provide data communication, RF transceiver modules operating in the ISM band or a dedicated data cable to/from data routers installed on a dedicated data trunk connected to a central Server (can also be connected via Ethernet/Internet/Fibre). Zoneworks software on the server is used to monitor, coordinate testing and collate test data from each fitting. Zoneworks Fittings can be commissioned by a single push of the test switch or by scanning the supplied barcode. The LED Test Switch indicator provides a multifunction indication of the status of the fitting during testing and normal operation:

Option	State	LED Operation
ZW, HVG, DATA	Commissioned	LED on Solid (Green)
ZW, DATA	Un-commissioned	Batt plugged-in: yellow 1s, green 1s
		Batt unplugged: red 1s, off 1s
HVG	Un-commissioned	Batt plugged-in: yellow 1s, green 1s
	With network connectivity	Batt unplugged: red 1s, off 1s
HVG	Un-commissioned	Batt plugged-in: yellow 250mS, green
	Without network connectivity	250mS, yellow 250mS, green 250mS,
		green 1s
		Batt unplugged: red 250mS, off
		250mS, red 250mS,off 250mS, off 1s
ZW, DATA	Emergency Light Test In Progress	LED flashes at yellow 5s, 0ff 1s
HVG	Emergency Light Test In Progress	LED flashes at yellow 1s, 0ff 1s

In the case of the DATA version a 2-way "figure 8" cable and terminal block facilitates the connection to the DATA network via a multi-drop bus (daisy chain connection). For further information of installation of a Zoneworks system, please refer to the Zoneworks Users Guide and Commissioning Guide (incl. DATA version)

# **DALI 2 EM Option**

Luminaires with part numbers having -D2 are fitted with DALI 2 certified modules (nodes) that facilitate connection and integration to 3rd Party Lighting Control Systems. Before installing the fitting please confirm that the Lighting Control System has the capability to monitor DALI Emergency Luminaires. The fitting will be addressed and configured into the control system by the Lighting Control System Commissioning Technicians and not Clevertronics

State	LED Operation
Commissioned/ Un-commissioned	LED on Solid (Green)
Emergency Light Test in progress	LED flashes at 1s On (Yellow) & 1s Off
"IDENTIFY COMMAND"	Lamp and Status LED Flash for 30 seconds

A 2-way "figure 8" cable and terminal block facilitates the connection to the DALI network OR a 5/6way "structured wiring system" lead and plug facilitating the power and DALI connection. DALI connections are marked as Da Da.

# Warranty:

For Product Warranty information and Terms and Conditions of Sales please refer to our website https://clevertronics.co.uk/product-warranty-statement/





# Argonaut PRO Weatherproof Emergency LED Batten Installation & Maintenance Instruction Leaflet



NOTE: Standard product codes with this symbol are enabled with Clevertest Plus capability. Please refer to the operation guide supplied with the product for details.



#### Australia (Head Office)

Website: www.clevertronics.com.au Email: info@clevertronics.com.au Phone: +61 3 9559 2700

#### **UK OFFICE**

Website: www.clevertronics.co.uk Email: sales@clevertronics.co.uk

Phone: 01895 430 255

## Models: ARGOPRO-1500-xx-L10POD-zz

Testing: Options:

Manual Test	zz = Blank	Microwave Sensor (HI/LO)	xx = SEN
Zoneworks	zz = ZW	DALI Driver	xx = DD
Z/W DATA	zz = DATA	5000K	xx = CW

Zoneworks HIVE zz = HVGDALI-2 zz = D2

# **Spare Parts:**

1533050 Replacement Battery

8002756 Replacement Emergency LED Board 8002757 Replacement Emergency LED Board (-CW)

LLIFE-PRO-CKIT-2PTSB Replacement Emergency Driver 1330072 Replacement 240V Driver

1330151 Replacement 240V Driver (-SEN) 1330073 Replacement 240V Driver (-DD)

# **Important:**

It is illegal for anyone, except for a licensed electrician to install or maintain this product. Before installation, ensure that the electricity supply has been switched off and isolated. Installation must be carried out in accordance with the relevant British Standards.

#### Caution:

On many building sites, power circuits may be cut off in an uncontrolled and repetitive basis during construction. As a result, any Exit & Emergency Units, on these circuits, will have their batteries discharged or "cycled". The Li-ion battery in the Exit & Emergency Unit has been selected to give excellent long life performance in a controlled IEC 60598-2-22 testing environment. Excessive battery cycling will reduce through-life performance and may lead to premature battery failure. Battery warranty claims, as a result of such abuse, are specifically EXCLUDED from Clevertronics warranty terms.

1940011

V1.0

24 June 2024

#### Installation:

The product can be mounted/suspended from any solid surface. Follow the below installation steps:


- Determine the installation and power entry method.
- Undo the Diffuser Clips, remove the Diffuser and Gear Tray. Position the batten base in the desired location and Mark out the fixing points on the mounting surface.
- If the cable entry is to be via the rear of the body Drill out a suitable entry-hole in the rear of the batten body (must be suitably sealed after cable entry using a sealant). If the cable entry is via the end of the batten - Install the provided cable gland, or bring in conduit, to the base as required for the intended power access.

Note: Only round cables are to be used with the cable gland for an IP65 seal. Keep cable entry straight and tension free. Ensure all seals are tight. min. wire diameter 7mm, max. 12mm.

- For surface mounting -, there are 3 extrusions/posts at each end of the base. Drill out the desired number of fixing points at each end. Fixings must only be through the extrusions/mounting posts.
  - Position the fitting to the mounting surface and mark the mounting holes. 0
  - Cable/Gland entry to be down if mounting vertically.
  - Drill the mounting holes.
  - Fix the base to the surface with appropriate fixings.
  - Seal any penetrations/fixing points with appropriate sealant.
- For Surface Mount Clip mounting, measure/mark spacing (see Dimensions image), install stainless steel clips to surface (use appropriate fixings), then snap batten into clips.
- For Suspension Mounting, measure/mark spacing (see Dimensions image), install suspension device, E.G chain, and connect chain to batten base.
- Wire mains power cable, 240V 50Hz, to terminals marked Lsw (Switched Active), Lem (Emergency/Unswitched Active), N & (and DALI Cable to terminals Da Da as applicable).
- Set Switch to the desired Lumen Output (6358lm | 8498lm, Default = 8498lm).
- Attach Gear Tray to lanyards.
- Re-Install the Diffuser, close all the Diffuser Clips and secure with screws.
- The luminaire should be positioned so that prolonged staring into the luminaire at a distance closer than 330mm is not expected.

If the CTP capabilities are activated, please affix the CTP status label to a visible surface and Four Segment Marking on the product will include an "F" in third segment block

# Wiring:




NOTE: Refer to Microwave Sensor Supplement for wiring -SEN Products

## Note:


This luminaire (with reinforced insulation between control/LED terminal and AC supply) contains non-user replaceable light source and battery - to be replaced (if required, refer installation instructions for battery replacement) by Clevertronics service personnel/agents or a registered electrician.

If flexible wiring is connected to this luminaire and is within arms reach, the wiring shall be effectively fixed to the wall to reduce the risk of strangulation.

### **Dimensions:**



# **Lumen Setting:**



# 6358m **→** 8498lm

# **Battery Replacement:**

- Prior to any work, isolate the power to the luminaire that requires battery replacement
- Remove fitting from mounting bracket.
- 3. Remove Emergency Driver cover from top and disconnect the battery connector.
- Remove rear diffuser cover and remove battery from holder.
- Replace battery and connect to Emergency Driver.
- Reinstall the rear diffuser cover and the Emergency Driver cover.
- 7. Reinstall the fitting onto the mounting bracket.
- Refit the diffuser retainer and diffuser, ensure diffuser is aligned to maintain the weatherproof seal.

# **Testing Procedure:**

When the unit is connected to the un-switched active, it must be allowed to charge the battery for at least 24 hours. The emergency lamp only illuminates during a power fail. Conduct the following tests:

- The emergency lamp must illuminate for at least 180 min after disconnection from the mains. If the unit fails to illuminate for the requisite time, remedial action must be taken to repair the situation and once completed, the unit must pass a subsequent test.
- Press and hold Test Button or switch Off Mains Supply, check that the emergency lamp is On.
- Release the Test Button or Switch On Mains Supply, check that the emergency lamp is Off (Nonmaintained operation).

# Trouble Shooting:

Below are a list of common problems and their possible causes.

The Green LED Test Switch indicator is not illuminated.

Check: A.C. is connected and is turned on.

Battery is connected Test Switch for damage.

Fault: Lamp does not illuminate in emergency mode.

Check: A.C. is connected.

> Lamp is correctly inserted. Battery is connected

Fault: Lamp illuminates in emergency mode, but only stays on for a short period.

Check: Battery has been allowed to charge for at least 24 hours.

Battery for damage.

V1.0

ON