Installation:

The L10 Vandal Proof LED Exit can be installed either Ceiling or Wall Mounted. When wall mounted, it can be flat/back to the wall or as a Flag extending from the wall.

All versions (Assembly preparation)

- Remove the 4 security screws which hold the assembly together.
- Remove the bottom cover frame whilst holding the side covers.
- Disengage the Cleverfit Pro from the slide connect bracket.
- Remove the terminal block cover.
- Remove the slide bracket from the top mounting frame.

Ceiling Mount

- Using the Top frame as a guide, mark 4 holes for mounting and one for mains access.
- Install the top frame to the ceiling using appropriate fixings (not supplied).
- Route the power cable through the access hole.
- Install the Cleverfit Pro slide bracket with the power cable through the access hole.
- Connect the power to the terminal block.
- Reinstall the terminal block cover.
- Reinstall the Cleverfit Pro Exit to the slide bracket

Wall Mount

- Using the solid Polycarbonate sheet as a guide, mark 4 holes for mounting and one for mains
- Install the solid Polycarbonate sheet to the wall using appropriate fixings (not supplied).
- Route the power cable through the access hole in the Polycarbonate.
- Position the top frame over the Polycarbonate sheet.
- Install the Cleverfit Pro slide bracket with the power cable through the cable entry.
- Connect the power to the terminal block.
- Reinstall the terminal block cover.
- Reinstall the Cleverfit Pro Exit to the slide bracket.

All versions (Final Assembly)

- Ensure the 2 clear slide covers are inserted back into the bottom frame
- Re-install the bottom frame to the top frame, whilst aligning the side covers into the top frame, using the 4 security screws which hold the assembly together.

Testing and Maintenance

Refer to the Cleverfit Pro Installation Instruction sheet provided with the fitting for all test and maintenance procedures.

Note that in order to scan the LED on the fitting for Clevertest Plus the bottom part of the vandal proof housing needs to be removed.

Rated Emergency Lumen Output in accordance with AS2293.1 (refer to spacing tables for installation positions): (N/A for -SP fittings)

Refer to the Technical Label for classification information.





L10™ LED Vandal Proof Exit Installation & Maintenance Instruction Leaflet



Designed in Australia to comply with the requirements

of AS2293.3: 2005 and AS/NZS CISPR15: 2017
NOTE: Standard product codes with this symbol enabled with Clevertest Plus capability. Please refer to the operation guide supplied with the product for details.

Victoria (Head Office & Manufacturing)

Website: www.clevertronics.com.au Email: info@clevertronics.com.au

Phone: +61 3 9559 2700 Fax: +61 3 9559 2799

New South Wales

Phone: +61 2 8805 6400 Fax: +61 2 8805 6444

Queensland

Phone: +61 7 3442 9700 Fax: +61 7 3442 9777

South Australia/Northern Territory

Phone: +61 8 8301 8800 Fax: +61 8 8351 8286

Western Australia

Phone: +61 8 9248 3720 Fax: +61 8 9248 3725

New Zealand

Phone: +64 800 548 448

Models: LVELED-yy-xx-vv

Testing: Options: Wall Mount yy = WMManual Test xx = Blank Ceilina Mount yy = CMZoneworks xx = ZWFlag Mount yy = FMSpecial Sign Z/W DATA xx = DATAvv=SP

DALI xx = DALIDALL HIVF xx = HV

Clevertest xx = CT

> (NOTE: -CT Products supplied with the Clevertest Plus Symbol 😿 are activated with Clevertest PLUS capability. Please refer to the operation guide supplied with the product for details).

Important:

It is illegal for anyone, except for a licensed electrician to install or maintain this product. Before installation, ensure that the electricity supply has been switched off and isolated. Installation must be carried out in accordance with the relevant Australian and International Standards.

> 25 March 2020 1942352 V1.0

INSTALLATION IMAGES







