



Refer to the supplementary operation guide supplied with the Product.

# Zoneworks, HIVE (HV/HVG) and DATA Monitored Options

Fittings with part numbers -ZW, -HV, -HVG, -DATA are fitted with Zoneworks communications modules (nodes). These fittings are monitored using either Powerline Carrier Technology that utilize the power cable to provide data communication, RF transceiver modules operating in the ISM band or a dedicated data cable to/from data routers installed on a dedicated data trunk connected to a central Server (can also be connected via Ethernet/Internet/Fibre). Zoneworks software on the server is used to monitor, coordinate testing and collate test data from each fitting. Zoneworks Fittings can be commissioned by a single push of the test switch or by scanning the supplied barcode. The LED Test Switch indicator provides a multifunction indication of the status of the fitting during testing and normal operation:

Option	State	LED Operation	
ZW, HV, HVG, DATA	Commissioned	LED on Solid (Green)	
	Lin-commissioned	Batt plugged-in: yellow 1s, green 1s	
	on-commissioned	Batt unplugged: red 1s, off 1s	
	Un-commissioned	Batt plugged-in: yellow 1s, green 1s	
HV, HVG	With network connectivity	Batt unplugged: red 1s, off 1s	
HV, HVG	Un-commissioned Without network connectivity	Batt plugged-in: yellow 250mS, green 250mS, yellow 250mS, green 250mS, green 1s	
		Batt unplugged: red 250mS, off 250mS, red 250mS,off 250mS, off 1s	
ZW, DATA	Emergency Light Test In Progress	LED flashes at yellow 5s , 0ff 1s	
HV, HVG	Emergency Light Test In Progress	LED flashes at yellow 1s , 0ff 1s	

In the case of the DATA version a 2-way "figure 8" cable and terminal block facilitates the connection to the DATA network via a multi-drop bus (daisy chain connection). For further information of installation of a Zoneworks system, please refer to the Zoneworks Users Guide and Commissioning Guide (incl. DATA version)

# **DALI EM Option**

Luminaires with part numbers having -DALI are fitted with DALI modules (nodes) that facilitate connection and integration to 3<sup>rd</sup> Party Lighting Control Systems. Before installing the -DALI luminaire, please confirm that the Lighting Control System has the capability to monitor DALI Emergency Luminaires. The -DALI fitting will be addressed and configured into the control system by the Lighting Control System Commissioning Technicians and not Clevertronics.

State	LED Operation
Commissioned/ Un-commissioned	LED on Solid (Green)
Emergency Light Test in progress	LED flashes at 1s On (Yellow) & 1s Off
"IDENTIFY COMMAND"	Lamp and Status LED Flash for 30 seconds

A 2-way "figure 8" cable and terminal block facilitates the connection to the DALI network. DALI connections are marked as Da Da.

## Caution:

On many building sites, power circuits may be cut off in an uncontrolled and repetitive basis during construction. As a result, any Exit & Emergency Units, on these circuits, will have their batteries discharged or "cycled". The battery in this fitting has been selected to give excellent long-life performance in a controlled AS2293 testing environment. Excessive battery cycling will reduce through-life performance and may lead to premature battery failure. Battery warranty claims, as a result of such abuse, are specifically EXCLUDED from Clevertronics warranty terms.

# Rated Emergency Lumen Output in accordance with AS2293.1 (refer to spacing tables for installation positions):

Refer to the Technical Label for classification information.





Victoria (Head Office & Manufacturing)

# Argonaut PRO Weatherproof Emergency LED Batten Installation & Maintenance Instruction Leaflet



Phone: +61 2 8805 6400 Fax: +61 2 8805 6444

#### Queensland Phone: +61 7 3442 9700

**Fax:** +61 7 3442 9700 **Fax:** +61 7 3442 9777

South Australia/Northern Territory Phone: +61 8 8301 8800 Fax: +61 8 8351 8286

#### Western Australia

**Phone:** +61 8 9207 0000 **Fax:** +61 8 9207 0088

#### New Zealand

Phone: +64 800 548 448

)
FP

(NOTE: -CT Products supplied with the Clevertest Plus Symbol Are activated with Clevertest PLUS capability. Please refer to the operation guide supplied with the product for details).

#### **Spare Parts:**

1530050	Replacement Battery	
8002755	Replacement Emergency LED E	Board
8012110	Replacement Emergency LED E	Board (-940 Version only)
AUM01370120001	Replacement Emergency Driver	•
1330055	Replacement 240V Driver	
1330151	Replacement 240V Driver	(SEN version only)
1330056	Replacement 240V Driver	(DD version only)

Designed in Australia to comply with the requirements

of AS/NZS2293.3: 2018, AS CISPR 15: 2017

#### Important:

It is illegal for anyone, except for a licensed electrician to install or maintain this product. Before installation, ensure that the electricity supply has been switched off and isolated. Installation must be carried out in accordance with the relevant Australian and International Standards.

**Note:** This luminaire (with reinforced insulation between control/LED terminal and AC Supply) contains non-user replaceable light source and battery – to be replaced (if required, refer installation instructions for battery replacement) by the manufacturer or his service agent or a similar qualified person.

Instruction Sheet Template - V1.3 – Updated 20/01/2022

### Installation:

The product can be mounted/suspended from any solid surface. Follow the below installation steps:

- Determine the installation and power entry method.
- Undo the Diffuser Clips, remove the Diffuser and Gear Tray. Position the batten base in the desired location and Mark out the fixing points on the mounting surface.
- If the cable entry is to be via the rear of the body Drill out a suitable entry-hole in the rear of the batten body (must be suitably sealed after cable entry using a sealant). If the cable entry is via the end of the batten Install the provided cable gland, or bring in conduit, to the base as required for the intended power access.

Note: Only round cables are to be used with the cable gland for an IP65 seal. Keep cable entry straight and tension free. Ensure all seals are tight.

min. wire diameter 7mm, max. 12mm.

- For surface mounting -, there are 3 extrusions/posts at each end of the base. Drill out the desired number of fixing points at each end. Fixings must only be through the extrusions/mounting posts.
  - Position the fitting to the mounting surface and mark the mounting holes.
  - Cable/Gland entry to be down if mounting vertically.
  - Drill the mounting holes.
  - Fix the base to the surface with appropriate fixings.
  - Seal any penetrations/fixing points with appropriate sealant.
- For Surface Mount Clip mounting, measure/mark spacing (see Dimensions image), install stainless steel clips to surface (use appropriate fixings), then snap batten into clips.
- For Suspension Mounting, measure/mark spacing (see Dimensions image), install suspension device, E.G chain, and connect chain to batten base.
- Wire mains power cable, 240V 50Hz, to terminals marked Lsw (Switched Active), Lem

(Emergency/Unswitched Active), N & 🕒 (and DALI Cable to terminals Da Da as applicable)

- Set Switch to the desired Lumen Output (3541Im | 4660Im | 5495Im | 6259Im, Default = 4660Im)
- Attach Gear Tray to lanyards.
- Re-Install the Diffuser, close all the Diffuser Clips and secure with screws.
- The luminaire should be positioned so that prolonged staring into the luminaire at a distance closer than 330mm is not expected.

# Wiring:



NOTE: Refer to Microwave Sensor Supplement for wiring -SEN Products

# **Dimensions:**



# Lumen Setting:

(Not applicable to fixed lumen versions)

For -SEN products	refer to	the DIP	Switche	s on
the Driver.				



	1	2	3	4	5
3541lm (500mA)	ON	ON	-	-	-
4660lm (650mA)	-	ON	ON	-	-
5495lm (750mA)	-	-	-	-	ON
6259lm (900mA)	ON	ON	-	-	ON

# 3541lm 4660lm 5495lm 6259lm

**NOTE:** Recommended currents are 500mA, 650mA, 750mA & 900mA for this product. Using settings outside of the recommended will void warranty. Product must be de-energised before switching Lumen/Current.

#### **Testing:**

Once connected to the 240V mains supply, the unit must be allowed to charge the battery for at least 24 hours. Conduct the following tests:

- For the first test, the emergency lamp must remain illuminated for at least 2 hours after disconnection from the mains supply.
- Subsequent tests require the unit to illuminate for at least 90 minutes. The results of all tests are required to be recorded in a service logbook, which is to be kept on-site at all times. If the unit fails to remain illuminated for the requisite time, remedial action must be taken to repair the situation and once completed, the unit must pass a subsequent test. For more specific information, please refer to the current edition of the AS 2293.3 Standard.
- Press and hold Test Button or switch Off Mains Supply, check that the emergency lamp is On.
- Release the Test Button or Switch On Mains Supply, check that the emergency lamp is Off (Nonmaintained operation).

# **Trouble Shooting:**

Below are a list of common problems and their possible causes.

ault:	The Green LED	<b>Test Switch</b>	indicator is	not illuminated.

r aurt.	The oreen LED rest ownen indicator is not indimitated.
Check:	A.C. is connected and is turned on.
	Battery is connected
	Test Switch for damage.
Fault:	Lamp does not illuminate in emergency mode.
Check:	A.C. is connected.
	Lamp is correctly inserted.
	Battery is connected
Fault:	Lamp illuminates in emergency mode, but only stays on for a short period.
Check:	Battery has been allowed to charge for at least 24 hours.

Battery for damage.

# Warranty:

For Product Warranty information and Terms and Conditions of Sales please refer to our website <a href="http://clevertronics.com.au/terms-conditions-sale-australia-nz/">http://clevertronics.com.au/terms-conditions-sale-australia-nz/</a>