



CLIFE-SM-WP-CL-HVG-BLK

Lifelight IP65 Weatherproof Emergency, Surface Mount, LP, Zoneworks XT Hive, Corridor Lens, Black



PRODUCT INFORMATION

Part Number	CLIFE-SM-WP-CL-HVG-BLK
MIC	AUD02920090001
Description	Lifelight IP65 Weatherproof Emergency, Surface Mount, LP, Zoneworks XT Hive, Corridor Lens, Black
Construction	Polycarbonate Enclosure
Mounting	Surface Mounted
Dimensions L x W x H	247 x 129 x 51
Weight	0.8
Operating Mode	Non-maintained
Testing System	Zoneworks XT Hive (RF) 2.4GHz
Battery	Lithium Iron Phosphate, 3.2V 3200mAh
Charging Method	Intelligent Current Limited Constant Voltage
Lamp(s)	1 x High intensity LED
Operating Voltage	220-240V~50Hz
Power Factor	0.73
Power Consumption	1.3W (Standby), 4.5W (Max)
Inrush Current (Peak/ Duration)	0.3A/3668µs
Earth Leakage	N/A
IP Rating	IP65
IK Rating	IK08
Operating Temperature	0°C to 40°C
AS2293 Classification	C0= D40, C90=E20
Applicable Standards	AS/NZS3820, CISPR15, AS/NZS2293.3
Compliance Marking (RCM)	
Appliance Class	 Class II double insulated

REPLACEMENT PARTS

PART NUMBER	DESCRIPTION
1550030	Battery
8002941	Emergency Driver
8050174	LED Panel
8003560	Node

The product details described in this document are current as at the version date of the document. We reserve the right to change product design, specifications or materials (Specifications) as part of our continuous improvement program. Please confirm the applicable Specifications at the time of placing your order



CLIFE-SM-WP-CL-HVG-BLK

Lifelight IP65 Weatherproof Emergency, Surface Mount, LP,
Zoneworks XT Hive, Corridor Lens, Black

SPACING TABLE

Manufacturer recommended spacing table and mounting heights for $\leq 2.5\text{m}$ corridor width, based on direct illuminance calculations (AS/NZS 2293.1); minimum light level of 0.2lx / 0.5lx avg											
Mounting Height [m]	2.1	2.4	2.7	3.0	3.3	3.6	4.0	4.5	5.0	6.0	7.0
Fitting to Wall [m]	12.5	13.9	14.6	15.4	16.4	16.8	17.8	17.8	17.8	18.8	17.4
Fitting to Fitting [m]	33.1	35.9	38.5	40.7	42.7	44.6	46.8	43.1	51.2	54.2	42.8

Note: Spacing for mounting heights higher than 7.0m will depend on number of fittings used as the average of 0.5lx will change.
For specific requirements, different corridor widths and 1lx spacing tables please contact:
Clevertronics (info@clevertronics.com.au)

To determine actual spacings refer to section, 4.6.1.3 Illuminance calculations, of AS/NZS2293.1:2018.

ISOLUX LINE

