



RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-ARGOPRO1200

Date: 2 December 2025

We: Clevertronics Pty Ltd
1 Caribbean Drive
Scoresby VIC 3179 Australia
T: +61 3 9559 2700
E: Productenquiry@clevertronics.com.au
ABN: 64 136 264 349

Clevertronics Pty Ltd
Unit 22/761 Great South Road
Penrose, Auckland 1061, New Zealand
T: +64 800 548 448
E: Productenquiry@clevertronics.com.au
NZBN: 9429042377382

declare that the **ARGOPRO-1200-SEN-LP-HV** and following associated product codes

ARGOPRO-1200-ee
ARGOPRO-1200-aa-bb-cc-dd-ee
ARGOPRO-1200-aa-bb-cc-940-dd-ee

ARGOPRO-1200-CC-aa-bb-cc-dd
ARGOPRO-1200-CC-aa-bb-cc-940-dd

Where;

Wildcard	Description	Wildcard	Description
aa = Blank	Non-Sensor version	cc = HVG	Zoneworks XT HIVE (2.4GHz)
aa = SEN	MS Sensor Version	cc = DATA	Zoneworks DATA
aa = DD	DALI Driver Version	cc = DALI	DALI
bb = LP	LP Battery Inside the Batten	cc = D2	DALI-2
bb = LPPOD	LP Battery in Pod outside the Batten	dd = Blank	Standard fitting
bb = L10POD	L10 Battery in Pod outside the Batten	dd = 4HR	4-hr emergency run-time fitting
cc = Blank	Manual Test/Clevertest Plus (CTP)	ee = Blank	Housing Colour – White/RAL9010
cc = ZW	Zoneworks XT	ee = BLK	Housing Colour – Black
cc = HV	Zoneworks XT HIVE (915MHz)	ee = RAL xyzw	Housing Colour – where, x (first digit) can be 1-9 (colour system code number) yzw (last three digits) can be 000- 999 (specific shade within a colour group)

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC).

Above products meet the following standards:

AS/NZS 2293.3:2018	Emergency lighting and exit signs for buildings Emergency luminaires and exit signs
AS 60598.2.22:2019	Luminaires – Part 2.22: Particular requirements – Luminaires for emergency lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)
AS/NZS 60598.2.1:2014	Luminaires Particular requirements - Fixed general-purpose luminaires
AS CISPR 15:2017	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013+AMD1:2015 (ED.8.1) MOD)

Michael Duce
General Manager - Product and Technical Services

R-NZ

