



RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-CLEVERFIT

Date: 19 August 2025

We: Clevertronics Pty Ltd
1 Caribbean Drive
Scoresby VIC 3179 Australia
T: +61 3 9559 2700
E: Productenquiry@clevertronics.com.au
ABN: 64 136 264 349

Clevertronics Pty Ltd
Unit 22/761 Great South Road
Penrose, Auckland 1061, New Zealand
T: +64 800 548 448
E: Productenquiry@clevertronics.com.au
NZBN: 9429042377382

declare that the **CCFLED-HV** and following associated product codes

CCFLED-aa-bb-cc-dd-ee-ff
CCFLED-aa-bb-TPS-cc-dd-ee-ff
LCFLED-aa-bb-cc-dd-ee-ff
LCFLED-aa-bb-TPS-cc-dd-ee-ff

Where,

aa = Blank	Standard fitting	ee = Blank	One-box Solution
aa = TH	Theatre fitting	ee = E	EXIT Decal
bb = Blank	Manual Test/Clevertest Plus (CTP)	ee = R	Running Man Decal
bb = ZW	Zoneworks XT	ee = RL	Running Man Left Arrow Decal
bb = HV	Zoneworks XT HIVE	ee = RR	Running Man Right Arrow Decal
bb = HVG	Zoneworks XT HIVE	ee = SP	Special Purpose sign
bb = DATA	Zoneworks DATA	ee = DS-E	Double sided EXIT Decal
bb = DALI	DALI	ee = DS-R	Double sided Running Man Decal
bb = D2	DALI-2	ee = DS-RAOW	Double sided Running Man Arrow One Way Decal
cc = Blank	Standard fitting	ff = Blank	Housing Colour - Standard colour
cc = UPS	Changeover Central Supplied from a UPS (240V AC)	ff = BLK	Housing Colour - Black
cc = 4HR	4-hour emergency run-time fitting	ff = DULSN4H4	Housing Colour - Dulux Stepney
cc = 6HR	6-hour emergency run-time fitting		
dd = Blank	Non-Tamperproof version (default)	ff = "Custom colour code"	Housing Colour - custom define colour code
dd = TP	Tamperproof version		

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC).

Above products meet the following standards:

AS/NZS 2293.3:2018	Emergency lighting and exit signs for buildings Emergency luminaires and exit signs
AS 60598.2.22:2019	Luminaires – Part 2.22: Particular requirements – Luminaires for emergency lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)
AS CISPR 15:2017	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013+AMD1:2015 (ED.8.1) MOD)


Michael Duce

General Manager - Product and Technical Service

R-NZ 

Responsible Supplier Number E7500
Clevertronics is registered with ERAC EESS and ACMA