



RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-DYGC-CP_DYGL-CP

Date: 28 October 2021

We:	Clevertronics Pty Ltd	Clevertronics Pty Ltd
	1 Caribbean Drive	Unit 22/761 Great South Road
	Scoresby VIC 3179 Australia	Penrose, Auckland 1061, New Zealand
	T: +61 3 9559 2700	T: +64 800 548 448
	E: Productenquiry@clevertronics.com.au	E: Productenquiry@clevertronics.com.au

ABN: 64 136 264 349

NZBN: 9429042377382

declare that the DYGC-CP-R-HV and following associated product codes

DYGa-CP-bb-cc-dd-ee

DYGa-CP-bb-TH-cc-dd

Where,

a = L	L10 Battery
a = C	LP Battery
bb = Blank	No Sounder fitted
bb = SND-NO	Sounder fitted with Normally Open Contact
bb = SND-NC	Sounder fitted with Normally Closed Contact
cc = R	Running Man Decal
cc = RL	Left-Arrow Running-Man-Left Decal
cc = RR	Running-Man-Right Right-Arrow Decal
cc = DS-R	Double sided Running Man Decal
cc = DS-RAOW	Double sided Running Man Arrow One Way Decal
dd = Blank	Manual Test/Clevertest Plus (CTP)
dd = ZW	Zoneworks XT
dd = HV	Zoneworks XT HIVE
dd = DATA	Zoneworks DATA
dd = DALI	DALI Registered
ee = Blank	Default colour code - White
ee = BLK	Housing Colour- BLACK
ee = GRY	Housing Colour- Grey
ee = SLV	Housing Colour- Silver
ee = WHT	Housing Colour- White
ee = "Custom colour code"	Custom defined colour code



RCM DECLARATION OF CONFORMITY

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC).

Above products meet the following standards:

AS/NZS 2293.3:2018

Emergency lighting and exit signs for buildings
Emergency luminaires and exit signs

AS 60598.2.22:2019

Luminaires – Part 2.22: Particular requirements – Luminaires
for emergency lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)

AS CISPR 15:2017

Limits and methods of measurement of radio disturbance
characteristics of electrical lighting and similar equipment
(CISPR 15:2013+AMD1:2015 (ED.8.1) MOD)

Michael Duce

National Systems and Engineering
Manager

