



RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-EPIC1200

Date: 7 April 2025

We: Clevertronics Pty Ltd
1 Caribbean Drive
Scoresby VIC 3179 Australia
T: +61 3 9559 2700
E: Productenquiry@clevertronics.com.au
ABN: 64 136 264 349

Clevertronics Pty Ltd
Unit 22/761 Great South Road
Penrose, Auckland 1061, New Zealand
T: +64 800 548 448
E: Productenquiry@clevertronics.com.au
NZBN: 9429042377382

declare that the **EPIC-1200-LP** and following associated product codes

EPIC-1200
EPIC-1200-DD
EPIC-1200-SEN

EPIC-1200-EM
EPIC-1200-DD-EM
EPIC-1200-SEN-EM

EPIC-1200-LP-aa
EPIC-1200-DD-LP-aa
EPIC-1200-SEN-LP-aa

Where,

Wildcard	Description	Wildcards	Description
aa = Blank	Manual Test/Clevertest Plus (CTP)	aa = ZW	Zoneworks XT
aa = DALI	DALI Emergency Testing	aa = HV	Zoneworks XT HIVE (915MHz)
aa = D2	DALI-2 Emergency Testing	aa = HVG	Zoneworks XT HIVE (2.4GHz)
aa = DATA	Zoneworks DATA		

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC).

Above products meet the following standards:

AS/NZS 2293.3:2018	Emergency lighting and exit signs for buildings Emergency luminaires and exit signs
AS 60598.2.22:2019	Luminaires – Part 2.22: Particular requirements – Luminaires for emergency lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)
AS/NZS 60598.2.1:2014	Luminaires Particular requirements – Fixed general-purpose luminaires
AS CISPR 15:2017	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013+AMD1:2015 (ED.8.1) MOD)

Michael Duce
National Systems and Engineering Manager

