



RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-BOXLITEEXIT

Date: 28 October 2021

We: Clevertronics Pty Ltd
1 Caribbean Drive
Scoresby VIC 3179 Australia
T: +61 3 9559 2700
E: Productenquiry@clevertronics.com.au
ABN: 64 136 264 349

Clevertronics Pty Ltd
Unit 22/761 Great South Road
Penrose, Auckland 1061, New Zealand
T: +64 800 548 448
E: Productenquiry@clevertronics.com.au
NZBN: 9429042377382

declare that the LBLLED-WM-HV and the following associated product codes

LBLLED-aa-bb-cc-dd-ee-ff-gg

Where,

aa = WM	Wall Mount
aa = CM	Ceiling Mount
aa = SMS-WM	Surface Mount
aa = REC-WM	Recessed Wall Mount
bb = Blank	Manual Test
bb = CT	Clevertest (Self Diagnostics)
bb = ZW	Zoneworks XT
bb = HV	Zoneworks XT HIVE
bb = DATA	Zoneworks DATA
bb = DALI	DALI Registered
cc = Blank	Standard fitting (Default)
cc = 4HR	4-hour emergency run-time fitting
dd = Blank	One-box solution
dd = R	Running Man
dd = RL	Running Man Left
dd = RR	Running Man Right
dd = RAOW	Running Man Arrow One Way Decal
dd = VR	Vertical Running Man Decal
ee = Blank	Standard fitting
ee = 4HR	4-hour emergency run-time fitting
ff = Blank	Standard fitting
ff = BLK	Black colour
ee = Blank	Changeover Supply from self-contained battery – Default
gg = UPS	Changeover Central Supplied from a UPS (240V AC)



RCM DECLARATION OF CONFORMITY

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC).

Above products meet the following standards:

AS/NZS 2293.3:2018

Emergency lighting and exit signs for buildings
Luminaires and exit signs

AS 60598.2.22:2019

Luminaires – Part 2.22: Particular requirements – Luminaires
for emergency lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)

AS CISPR 15:2017

Limits and methods of measurement of radio disturbance
characteristics of electrical lighting and similar equipment
(CISPR 15:2013+AMD1:2015 (ED.8.1) MOD)

Michael Duce

National Systems and Engineering
Manager

