



# RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-LCWELED

Date: 27 February 2025

We: Clevertronics Pty Ltd  
1 Caribbean Drive  
Scoresby VIC 3179 Australia  
T: +61 3 9559 2700  
E: [Productenquiry@clevertronics.com.au](mailto:Productenquiry@clevertronics.com.au)  
ABN: 64 136 264 349

Clevertronics Pty Ltd  
Unit 22/761 Great South Road  
Penrose, Auckland 1061, New Zealand  
T: +64 800 548 448  
E: [Productenquiry@clevertronics.com.au](mailto:Productenquiry@clevertronics.com.au)  
NZBN: 9429042377382

declare that the **LCWELED** and following associated product codes

LCWELED-aa-bb-cc

LCWELED-aa-DS-bb-cc

Where;

Wildcard	Description	Wildcard	Description
aa = Blank	Manual Test/Clevertest Plus (CTP)	bb = R	Running Man Decal
aa = ZW	Zoneworks XT	bb = RL	Running Man Left Decal
aa = HV	Zoneworks XT HIVE (915MHz)	bb = RR	Running Man Right Decal
aa = HVG	Zoneworks XT HIVE (2.4GHz)	bb = RAOW	Running Man Arrow One Way Decal
aa = DALI	DALI	bb = SP	Special Purpose sign
aa = D2	DALI-2	cc = Blank	White Base
		cc = BBLK	Black Base

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC)

Above products meet the following standards:

AS/NZS 2293.3:2018

Emergency lighting and exit signs for buildings Emergency luminaires and exit signs

AS 60598.2.22:2019

Luminaires – Part 2.22: Particular requirements – Luminaires for emergency lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)

AS CISPR 15:2017

Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013+AMD1:2015 (ED.8.1) MOD)

**Michael Duce**

General Manager - Product and Technical Services

