

RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-WeatherproofSupalite

Date: 12 July 2021

We: Clevertronics Pty Ltd Clevertronics Pty Ltd

1 Caribbean Drive Unit 22/761 Great South Road

Scoresby VIC 3179 Australia Penrose, Auckland 1061, New Zealand

T: +61 3 9559 2700 T: +64 800 548 448

E: Productenquiry@clevertronics.com.au E: Productenquiry@clevertronics.com.au

ABN: 64 136 264 349 NZBN: 9429042377382

declare that the CWFLED-HV and following associated product codes

CWFLED-xx-uu-yy LWFLED-xx-uu-yy CWFLED-xx-vv-yy LWFLED-xx-vv-yy

Where,

xx = Blank Manual Test/Clevertest Plus (CTP)

xx = ZW Zoneworks

xx = HVZoneworks XT HIVExx = DATAZoneworks DATAxx = DALIDALI Registered

yy = Blank White Housing Colour yy = BLK Black Housing Colour

uu = Blank Normal cable between Driver and Lamp version

uu = 2IPREM Remote version with 10m long cable between Driver and Lamp

vv = Blank Fitting with 2-hour emergency running time vv = 4HR Fitting with 4-hour emergency running time

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC).

these products meet the following standards:

AS/NZS 2293.3:2018 Emergency lighting and exit signs for buildings Emergency luminaires

and exit signs

AS 60598.2.22:2019 Luminaires - Part 2.22: Particular requirements - Luminaires for

emergency lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)

AS CISPR 15:2017 Limits and methods of measurement of radio disturbance

characteristics of electrical lighting and similar equipment (CISPR

15:2013+AMD1:2015 (ED.8.1) MOD)



RCM DECLARATION OF CONFORMITY

MM

Michael Duce National Systems and Engineering Manager

