



RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-WeatherproofSupalite

Date: 2 July 2025

We: Clevertronics Pty Ltd
1 Caribbean Drive
Scoresby VIC 3179 Australia
T: +61 3 9559 2700
E: Productenquiry@clevertronics.com.au
ABN: 64 136 264 349

Clevertronics Pty Ltd
Unit 22/761 Great South Road
Penrose, Auckland 1061, New Zealand
T: +64 800 548 448
E: Productenquiry@clevertronics.com.au
NZBN: 9429042377382

declare that the CWFLED-HV and following associated product codes

CWFLED-aa-bb-cc-dd

LWFLED-aa-bb-cc-dd

Where;

Wildcard	Description	Wildcard	Description
aa = Blank	Manual Test/Clevertest Plus (CTP)	bb = Blank	Normal version - cable between Driver and Lamp
aa = ZW	Zoneworks XT	bb = 2IPREM	Remote version with 10m long cable between Driver and Lamp
aa = HV	Zoneworks XT HIVE (915MHz)	cc = Blank	Fitting with 2-hour emergency running time
aa = HVG	Zoneworks XT HIVE (2.4GHz)	cc = 4HR	Fitting with 4-hour emergency running time
aa = DATA	Zoneworks DATA	dd = WHT	Housing Colour – White
aa = DALI	DALI	dd = BLK	Housing Colour – Black
aa = D2	DALI-2	dd = "Custom colour code"	Housing Colour – custom defined colour code, RAL code



RCM DECLARATION OF CONFORMITY

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC)
- New Zealand Gazette Radiocommunications (Compliance) Notice 2020 and Radiocommunications Regulations (Radio Standards) Notice 2023

Above products meet the following standards:

AS/NZS 2293.3:2018	Emergency lighting and exit signs for buildings Emergency luminaires and exit signs
AS 60598.2.22:2019	Luminaires – Part 2.22: Particular requirements – Luminaires for emergency lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)
AS/NZS 60598.2.1:2014/Amdt:2019	Luminaires Particular requirements – Fixed general purpose Luminaires
AS CISPR 15:2017	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013+AMD1:2015 (ED.8.1) MOD)

Michael Duce
General Manager - Product and Technical Services

R-NZ

