



RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-WEATHERPROOFEXIT24M

Date: 28 October 2021

We: Clevertronics Pty Ltd
1 Caribbean Drive
Scoresby VIC 3179 Australia
T: +61 3 9559 2700
E: Productenquiry@clevertronics.com.au
ABN: 64 136 264 349

Clevertronics Pty Ltd
Unit 22/761 Great South Road
Penrose, Auckland 1061, New Zealand
T: +64 800 548 448
E: Productenquiry@clevertronics.com.au
NZBN: 9429042377382

declare that the CWELED-HV and the following associated product codes

aWELED-bb-cc-dd-ee-ff

aWELED-A-bb-cc-dd-ee-ff

aWELED-TH-bb-cc-dd-ee

aWELED-bb-WM-cc-dd-gg-ff

aWELED-bb-WM-IPREM-cc-dd-ff

aWELED-bb- FZR-gg-ff

aWELED-bb- FZR-IPREM-gg-ff

Where,

a = L L10 Battery
a = C LP Battery

bb = Blank Manual Test/Clevertest Plus (CTP)
bb = ZW Zoneworks XT
bb = HV Zoneworks XT HIVE
bb = DATA Zoneworks DATA
bb = DALI DALI Registered

cc = Blank Standard fitting (Default)
cc = 4HR 4-hour emergency run-time fitting

dd = Blank Non-Tamperproof version (Default)
dd = TP Tamperproof version

ee = Blank Changeover Supply from self-contained battery – Default
ee = UPS Changeover Central Supply from a UPS (240VAC)

ff = Blank Housing Colour (Default)
ff = BLK Housing Colour – Black
ff = “Custom colour code” Custom defined colour code

gg = Blank One-box Solution
gg = E EXIT Decal
gg = R Running Man Decal
gg = RL Running Man Left Arrow Decal
gg = RR Running Man Right Arrow Decal
gg = DS-E Double sided EXIT Decal
gg = DS-R Double sided Running Man Decal
gg = VR Vertical Running Man Decal

Responsible Supplier Number E7500
Clevertronics is registered with ERAC EESS and ACMA



RCM DECLARATION OF CONFORMITY

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC).

The above products meet requirements of the following standards:

AS/NZS 2293.3:2018	Emergency lighting and exit signs for buildings - Emergency luminaires and exit signs
AS 60598.2.22:2019	Luminaires – Part 2.22: Particular requirements – Luminaires for emergency Lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)
AS CISPR 15:2017	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013+AMD1:2015 (ED.8.1) MOD)

Michael Duce
National Systems and Engineering
Manager

