



RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-WEATHERPROOFEXIT24M

Date: 12 July 2022

We: Clevertronics Pty Ltd
1 Caribbean Drive
Scoresby VIC 3179 Australia
T: +61 3 9559 2700
E: Productenquiry@clevertronics.com.au
ABN: 64 136 264 349

Clevertronics Pty Ltd
Unit 22/761 Great South Road
Penrose, Auckland 1061, New Zealand
T: +64 800 548 448
E: Productenquiry@clevertronics.com.au
NZBN: 9429042377382

declare that the CWELED-HV and the following associated product codes

aWELED-bb-cc-dd-ee-ff
aWELED-A-bb-cc-dd-ee-ff
aWELED-bb-WM-cc-dd-gg-ff
aWELED-bb- FZR-gg-ff
aWELED-bb-NP3C-FP

aWELED-bb-cc-dd-SP-ee-ff
aWELED-TH-bb-cc-dd-ee
aWELED-bb-WM-IPREM-cc-dd-ff
aWELED-bb- FZR-IPREM-gg-ff

Where,

a = L L10 Battery

a = C LP Battery

bb = Blank	Manual Test/Clevertest Plus (CTP)	ff = Blank	Housing Colour - Standard colour
bb = ZW	Zoneworks XT	ff = "Custom colour code"	Custom defined colour code
bb = HV	Zoneworks XT HIVE	gg = Blank	One-box Solution
bb = HVG	Zoneworks XT HIVE	gg = E	EXIT Decal
bb = DATA	Zoneworks DATA	gg = R	Running Man Decal
bb = DALI	DALI Registered	gg = RL	Running Man Left Arrow Decal
cc = Blank	2-hour emergency running time	gg = RR	Running Man Right Arrow Decal
cc = 4HR	4-hour emergency run-time fitting	gg = SP	Special Purpose sign
dd = Blank	Standard fitting (Default)	gg = DS-E	Double sided EXIT Decal
dd = TP	Tamperproof Version	gg = DS-R	Double sided Running Man Decal
ee = Blank	Changeover Supply from self-contained battery - Default	gg = DS-RAOW	Double sided Running Man One Way
ee = UPS	Changeover Central Supplied from a UPS (240V AC)	gg = VR	Vertical Running Man Decal

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC).

The above products meet requirements of the following standards:

AS/NZS 2293.3:2018

Emergency lighting and exit signs for buildings - Emergency luminaires and exit signs

AS 60598.2.22:2019

Luminaires - Part 2.22: Particular requirements - Luminaires for emergency Lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)

AS CISPR 15:2017

Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013+AMD1:2015 (ED.8.1) MOD)

Michael Duce

National Systems and Engineering Manager

