



RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM- ARGONAUTSQUARE

Date: 13 May 2022

We: Clevertronics Pty Ltd
1 Caribbean Drive
Scoresby VIC 3179 Australia
T: +61 3 9559 2700
E: Productenquiry@clevertronics.com.au
ABN: 64 136 264 349

Clevertronics Pty Ltd
Unit 22/761 Great South Road
Penrose, Auckland 1061, New Zealand
T: +64 800 548 448
E: Productenquiry@clevertronics.com.au
NZBN: 9429042377382

declare that the **CWSQLEDM-MS-HL-HV** and following associated product codes

- | | |
|----------------------------|---------------------|
| CWSQLEDM-aa-bb-cc | FWSQLED-bb-cc |
| CWSQLEDM-DD-aa-bb-cc | FWSQLED-DD-bb-cc |
| CWSQLEDM-MS-aa-bb-cc | FWSQLED-MS-bb-cc |
| CWSQLEDM-MS-HL-aa-bb-cc | FWSQLED-MS-HL-bb-cc |
| CWSQLEDM-LO-MS-HL-aa-bb-cc | ARGOSQ |
| LWSQLEDN-aa-bb-cc | ARGOSQ-DD |
| ARGOSQ-LP-aa | ARGOSQ-SEN |
| ARGOSQ-DD-LP-aa | |
| ARGOSQ-SEN-LP-aa | |

Where;

aa = Blank	Manual Test/Clevertest Plus (CTP)	bb = Blank	Standard version
aa = ZW	Zoneworks	bb = TP	Tamperproof screws version
aa = HV	Zoneworks XT HIVE	cc = Blank	Housing Colour – White
aa = HVG	Zoneworks XT HIVE	cc = BLK	Housing Colour – Black
aa = DATA	Zoneworks DATA	cc = Custom	Housing Colour – Custom colour code
aa = DALI	DALI Registered		

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC).

Above products meet the following standards:

- | | |
|-----------------------|--|
| AS/NZS 2293.3:2018 | Emergency lighting and exit signs for buildings Emergency luminaires and exit signs |
| AS 60598.2.22:2019 | Luminaires – Part 2.22: Particular requirements – Luminaires for emergency lighting (IEC 60598-2-22:2017 (ED.4.1) MOD) |
| AS/NZS 60598.2.1:2014 | Luminaires Particular requirements - Fixed general-purpose luminaires |
| AS CISPR 15:2017 | Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013+AMD1:2015 (ED.8.1) MOD) |

Michael Duce
National Systems and Engineering Manager

