



# RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-JUMBOWEATHERPROOFEXIT

Date: 21 May 2021

We: 

Clevertronics Pty Ltd 1 Caribbean Drive Scoresby VIC 3179 Australia T: +61 3 9559 2700 E: <a href="mailto:Productenquiry@clevertronics.com.au">Productenquiry@clevertronics.com.au</a> ABN: 64 136 264 349	Clevertronics Pty Ltd Unit 22/761 Great South Road Penrose, Auckland 1061, New Zealand T: +64 800 548 448 E: <a href="mailto:Productenquiry@clevertronics.com.au">Productenquiry@clevertronics.com.au</a> NZBN: 9429042377382
--	---

declare that the LJWELED-40-HV-WM-R and following associated product codes

LJWELED-40-xx-yy-rr-vv  
CJWELED-40-xx-yy-rr-vv

LJWELED-yy-40-xx-rr-vv  
CJWELED-yy-40-xx-rr-vv

Where,

xx = Blank	Manual Test/Clevertest Plus (CTP)
xx = ZW	Zoneworks
xx = HV	Zoneworks XT HIVE
xx = DATA	Zoneworks DATA
xx = DALI	DALI Registered
yy = Blank	Standard version
yy = CM	Ceiling Mount version
yy = WM	Wall Mount version
yy = WM-FZR	Wall Mount version (Low Temperature Applications)
rr = Blank	Standard fitting
rr = IPREM	IP66/67 remote controlgear
vv = E	EXIT Decal
vv = R	Running Man Decal
vv = RL	Running Man Left Arrow Decal
vv = RR	Running Man Right Arrow Decal
vv = DS-E	Double sided EXIT Decal
vv = DS-R	Double sided Running Man Decal
vv = DS-RAOW	Double sided Running Man Arrow One Way Decal
vv = SP	Special Purpose sign

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992



## RCM DECLARATION OF CONFORMITY

- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC).

Above products meet the following standards:

AS/NZS 2293.3:2018	Emergency lighting and exit signs for buildings Emergency luminaires and exit signs
AS 60598.2.22:2019	Luminaires – Part 2.22: Particular requirements – Luminaires for emergency lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)
AS CISPR 15:2017	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013+AMD1:2015 (ED.8.1) MOD)

**Michael Duce**  
National Systems and Engineering  
Manager

