



RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-LIFELIGHT
Date: 10 November 2021
We: Clevertronics Pty Ltd
1 Caribbean Drive
Scoresby VIC 3179 Australia
T: +61 3 9559 2700
E: Productenquiry@clevertronics.com.au
ABN: 64 136 264 349

Clevertronics Pty Ltd
Unit 22/761 Great South Road
Penrose, Auckland 1061, New Zealand
T: +64 800 548 448
E: Productenquiry@clevertronics.com.au
NZBN: 9429042377382

declare that the CLIFE-HV and following associated product codes

aBS2N
aBS4N
aLIFE-bb-cc-dd-ee-ff
aLIFE-SMS-dd-ff
aLIFE-SM-gg-cc-dd-ee-ff
aLIFE-WPPOD-CKIT-dd

Where,

a = L	L10 Battery
a = C	LP Battery
bb = Blank	Non-splashproof
bb = RECSP	Splashproof version
bb = SMPC	Surface Mount Polycarbonate
bb = TP	Tamper Proof
cc = Blank	Standard Lens
cc = CL	Lifelight Head with Corridor Lens version
cc = 2CL	2 x Lifelight Heads with Corridor Lenses version
dd = Blank	Manual Test/Clevertest Plus (CTP)
dd = ZW	Zoneworks XT
dd = HV	Zoneworks XT HIVE
dd = DATA	Zoneworks DATA
dd = DALI	DALI Registered
ee = Blank	Standard IEC Cable
ee = F3C	Custom 3-Core Cable
ee = F5C	Custom 5-Core Cable
ee = NCIL	Status LED shows only Red colour
ee = 4HR	4-hour emergency run-time fitting
ff = Blank	Housing colour – White
ff = BLK	Housing colour – Black
ff = DULSN4H4	Housing colour – Dulux Stepney
ff = RAL1013	Housing colour – RAL1013
ff = RAL9006	Housing colour – RAL1013
ff = "Custom colour code"	Housing colour – Custom defined colour code
gg = Blank	Non-weatherproof version
gg = WP	Weatherproof version



RCM DECLARATION OF CONFORMITY

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC).

Above products meet requirements of the following standards:

AS/NZS 2293.3:2018	Emergency lighting and exit signs for buildings - Emergency luminaires and exit signs
AS 60598.2.22:2019	Luminaires – Part 2.22: Particular requirements – Luminaires for emergency lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)
AS CISPR 15:2017	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013+AMD1:2015 (ED.8.1) MOD)

Michael Duce
National Systems and Engineering
Manager

