



DYGL-CP-RL

CleverEvac Dynamic Green Exit, Surface Mount, L10 Nanophosphate, Running Man Arrow Left, Single Sided



Dynamic LEDs Sequencing Arrow

PRODUCT INFORMATION

Part Number	DYGL-CP-RL
MIC	AUA01550120001
Description	CleverEvac Dynamic Green Exit, Surface Mount, L10 Nanophosphate, Running Man Arrow Left, Single Sided
Construction	PC/ABS body with PC diffuser
Mounting	Ceiling / Wall mounted single sided
Dimensions L x W x H	367mm x 72mm x 214mm
Weight	2.0kg
Operating Mode	Maintained – Sequencing inward green LED activated on VF/24V input trigger and capable of being activated in power-on and battery-backed mode. Dynamic GREEN default set to activate upon mains power fail
Testing System	Manual Test
Battery	Lithium Nanophosphate, 3.3V 2500mAh
Charging Method	Intelligent current limited constant voltage
Diffuser	Pictograph, Two elements (Running Man and Arrow Left)
Lamp(s)	LED panel, 100,000 hours
Operating Voltage	240V AC; 50Hz
Supply Current	0.091A
Power Factor	0.415
Power Consumption	1.8 Watts (Standby), 4.7 Watts (Max)
Inrush Current (Peak/Duration)	17.4A / 132µs
Earth Leakage	0.360mA
IP Rating	IP20
Operating Temperature	1°C to 40°C
AS2293 Classification	C0=E2.5, C90=E1.6, C270=E1.6, C180=B2
Viewing Distance	24m
Applicable Standards	AS/NZS3820, CISPR15, AS/NZS2293.3, Codemark CM20237 (AUS), CM20236 (NZ)
Compliance Marking (RCM)	

REPLACEMENT PARTS

PART NUMBER	DESCRIPTION
1530030	Battery
8002927	Emergency Driver
8003025	LED Panel

Disclaimer: Clevertronics Pty Ltd is a vendor of CleverEVAC products. It is not a fire engineer or designer. It does not purport to recommend its products for use in any particular application or to achieve any particular outcome. Purchasers and users of its products must take their own steps to ensure compliance with statutory requirements, safe practice and suitable application of the products. The product details described in this document are current as at the version date of the document. We reserve the right to change product design, specifications or materials (Specifications) as part of our continuous improvement program. Please confirm the applicable Specifications at the time of placing your order.