

**DYRC-UP-CM-R** CleverEvac Dynamic Red X Exit, Ceiling Mount, LP, Running Man, Single Sided



| PRODUCT INFORMATION      |   |
|--------------------------|---|
| Part Number              | DYRC-UP-CM-R  |
| MIC                      | AUA02550550001  |
| Description              | CleverEvac Dynamic Red X Exit, Ceiling Mount, LP, Running Man, Single Sided,<br>with Volt Free (VF) & 24V Interface for ON/OFF Activation of Dynamic Green &<br>Red X Enhancement.  |
| Construction             | PC/ABS Body with PC Diffuser and Metal Enclosure  |
| Mounting                 | Ceiling Mount, Single-sided   |
| Dimensions L x W x H     | 391mm x 90mm x 257mm  |
| Weight                   | 5.9 kg  |
| Operating Mode           | Maintained – Sequencing Inward Green LEDs or Illuminated Red X with Side<br>Flashing Red LED's Activated on VF/24V Input Trigger and Capable of Being<br>Activated in Power-on and Battery-backed Mode. Dynamic Green Default<br>Set to Activate Upon Mains Power Fail. |
| Testing System           | Manual  |
| Battery                  | Lithium Iron Phosphate, 3.2V 6400mAh  |
| Charging Method          | Intelligent Current Limited Constant Voltage  |
| Diffuser                 | Single-sided Pictograph, (Running Man)  |
| Lamp(s)                  | LED Panel, 100,000 hours  |
| Operating Voltage        | 220-240V AC; 50Hz   |
| Power Consumption        | 1.7W (Standby), 8.7W (Max)  |
| IP Rating                | IP20  |
| Operating Temperature    | 1°C to 40°C   |
| AS2293 Classification    | C0=E2.5, C90=E8   |
| Viewing Distance         | 24m   |
| Applicable Standards     | AS/NZS3820, CISPR15, AS/NZS2293.3   |
| Compliance Marking (RCM) |   |

| REPLACEMENT PARTS              |                       |
|--------------------------------|-----------------------|
| PART NUMBER                    | DESCRIPTION           |
| 1550250                        | Battery               |
| AUM02570030001<br>DYRC-UP-CKIT | Emergency Driver Pack |

**Disclaimer:** Clevertronics Pty Ltd is a vendor of CleverEVAC products. It is not a fire engineer or designer. It does not purport to recommend its products for use in any application or to achieve any particular outcome. Purchasers and users of its products must take their own steps to ensure compliance with statutory requirements, safe practice, and suitable application of the products.

