



LLIFE-PRO-SM-WL-HV-BLK

Lifelight Pro Emergency, Surface Mount, L10 Nanophosphate, Zoneworks XT Hive, Warehouse Lens, Black



PRODUCT INFORMATION

Part Number	LLIFE-PRO-SM-WL-HV-BLK
MIC	AUT01810570001
Description	Lifelight Pro Emergency, Surface Mount, L10 Nanophosphate, Zoneworks Hive, Warehouse Lens, Black
Construction	Polycarbonate Enclosure
Mounting	Surface Mounted
Dimensions L x W x H	247mm x 129mm x 51mm
Weight	0.8kg
Operating Mode	Non-maintained
Testing System	Zoneworks Hive (RF)
Battery	Lithium Nanophosphate, 3.3V 5000mAh
Charging Method	Intelligent Current Limited Constant Voltage
Lamp(s)	LED (Lifetime warranty on the lamp head and loom assembly)
Operating Voltage	240V AC; 50Hz
Power Consumption	0.7W (Standby) 3.0W (Max)
Inrush Current (Peak/Duration)	13.313A/66µs
Earth Leakage	N/A
IP Rating	IP20
IK Rating	IK08
Operating Temperature	0°C to 40°C
AS2293 Classification	N/A –Refer to Manufacturers' Recommended Spacing Table on the next page
Applicable Standards	AS/NZS3820, CISPR15, AS/NZS2293.3
Compliance Marking (RCM)	
Appliance Class	<input type="checkbox"/> Class II double insulated

REPLACEMENT PARTS

PART NUMBER	DESCRIPTION
1530231	Battery
8003501	Driver
8003191	HIVE Node
8050880	LED Strip

The product details described in this document are current as at the version date of the document. We reserve the right to change product design, specifications or materials (Specifications) as part of our continuous improvement program. Please confirm the applicable Specifications at the time of placing your order



LLIFE-PRO-SM-WL-HV-BLK

Lifelight Pro Emergency, Surface Mount, L10 Nanophosphate,
Zoneworks XT Hive, Warehouse Lens, Black

SPACING TABLE

Manufacturer recommended spacing table and mounting heights for $\leq 3.6\text{m}$ aisle width, based on direct illuminance calculations (AS/NZS 2293.1); minimum light level of 0.2lx / 0.5lx avg

Mounting Height [m]	6.0	7.0	8.0	9.0	10.0	11.0	12.0	13.0	14.0
Fitting to Wall [m]	23.2	25.2	27.5	30.2	32.0	33.6	34.6	35.6	38.6
Fitting to Fitting [m]	55.0	61.1	66.8	72.1	74.2	58.6	45.0	33.5	18.3

Note: These spacing tables are a guide to assist with placement of the emergency luminaire and any design must be verified via illuminance calculations in accordance with AS/NZS212931.2018, section 4.6.1.3 *Illuminance calculations*

ISOLUX PATTERN

