



LUBPRO-SM-RS-HVG

Ultrablade Pro Exit , Surface Mount, Rod Suspended, L10 Nanophosphate, Zoneworks XT Hive 2.4GHz, All Pictograms, Single or Double Sided



PRODUCT INFORMATION

Part Number	LUBPRO-SM-RS-HVG			
MIC	UKA01810140001			
Description	Ultrablade Pro Exit , Surface Mount, Rod Suspended, L10 Nanophosphate, Zoneworks XT Hive 2.4GHz, All Pictograms, Single or Double Sided			
Construction	PC/ABS body with PC Diffuser			
Mounting	Surface Mount Ceiling - Rod suspended Blade suspended with 5mm diameter; steel rods secured by 2 x "grub-screw" at each end of the rod. Rod suspension system supplies power to the LED lamp bar mounted on top of blade. Note: Steel Rods supplied with fitting assembly, 1500mm long.			
Dimensions L x W x H	Blade Assembly 317mm x 8.7mm x 157mm Ceiling Mount Control Gear Enclosure: 360mm x 47mm x 72mm			
Cut-Out	350mm x 48mm			
Weight	1.5kg			
Operating Mode	Maintained			
Testing System	Zoneworks XT HIVE (RF)			
Battery	Lithium Nanophosphate 3.3V 2.5Ah			
Charging Method	Intelligent current limited constant voltage			
Diffuser	All Directional Inserts Included			
Lamp(s)	12 x Duris E3 LED, 100,000 hours			
Operating Voltage	240V AC; 50Hz			
Power Consumption	1.9 Watts (Standby), 4.1 Watts (Max)			
IP Rating	IP20			
Operating Temperature	0°C to 40°C			
Viewing Distance	30m			
Protection	<ul style="list-style-type: none"> Battery overvoltage & overcurrent protection Battery deep discharge protection Supply voltage polarity reversal protection Battery short-circuit protection (charging will resume upon removal of fault) Kit box (enclosure) of lamp control gear provides protection against accidental contacts with live parts 			
Luminaire Classification	X	1	AFG	180
Conformity	BS EN 60598-2-22, BS 5266			

REPLACEMENT PARTS

PART NUMBER	DESCRIPTION
1530030	Battery
8002951	Driver
8003330	Communications Node

Disclaimer: Clevertronics Pty Ltd is a vendor of CleverEVAC products. It is not a fire engineer or designer. It does not purport to recommend its products for use in any particular application or to achieve any particular outcome. Purchasers and users of its products must take their own steps to ensure compliance with statutory requirements, safe practice and suitable application of the products.