



## LUBPRO-SM-RS-HVG

Ultrablade Pro Exit, Surface Mount, Rod Suspended, L10 Nanophosphate, Zoneworks XT Hive, All Pictograms, Single or Double Sided



### PRODUCT INFORMATION

Part Number	LUBPRO-SM-RS-HVG				
MIC	UKA01810140002				
Description	Ultrablade Pro Exit, Surface Mount, Rod Suspended, L10 Nanophosphate, Zoneworks XT Hive, All Pictograms, Single or Double Sided				
Construction	PC/ABS body with PC Diffuser				
Mounting	Surface Mount Ceiling - Rod suspended Blade suspended with 5mm diameter; steel rods secured by 2 x "grub-screw" at each end of the rod. Rod suspension system supplies power to the LED lamp bar mounted on top of blade. Note: Steel Rods supplied with fitting assembly, 1500mm long.				
Dimensions L x W x H	Blade Assembly 317mm x 8.7mm x 157mm Ceiling Mount Control Gear Enclosure: 360mm x 47mm x 72mm				
Cut-Out	350mm x 48mm				
Weight	1.5kg				
Operating Mode	Maintained				
Testing System	Zoneworks XT HIVE (RF)				
Battery	Lithium Nanophosphate 3.3V 2.5Ah				
Charging Method	Intelligent current limited constant voltage				
Diffuser	All Directional Inserts Included				
Lamp(s)	12 x Duris E3 LED, 100,000 hours				
Operating Voltage	240V AC; 50Hz				
Power Consumption	1.9 Watts (Standby), 4.1 Watts (Max)				
IP Rating	IP20				
Operating Temperature	0°C to 40°C				
Viewing Distance	30m				
Protection	<ul style="list-style-type: none"><li>Battery overvoltage &amp; overcurrent protection</li><li>Battery deep discharge protection</li><li>Supply voltage polarity reversal protection</li><li>Battery short-circuit protection (charging will resume upon removal of fault)</li><li>Kit box (enclosure) of lamp control gear provides protection against accidental contacts with live parts</li></ul>				
Luminaire Classification	<table border="1"><tr><td>X</td><td>1</td><td>AFG</td><td>180</td></tr></table>	X	1	AFG	180
X	1	AFG	180		
Conformity	BS EN 60598-2-22, BS 5266				

### REPLACEMENT PARTS

PART NUMBER	DESCRIPTION
1533030	Battery
8003837	Driver
8003330	HIVE Node

**Disclaimer:** Clevertronics Pty Ltd is a vendor of CleverEVAC products. It is not a fire engineer or designer. It does not purport to recommend its products for use in any particular application or to achieve any particular outcome. Purchasers and users of its products must take their own steps to ensure compliance with statutory requirements, safe practice and suitable application of the products.