

LUBPRO

Ultrablade Pro Exit, Recessed Ceiling Mount, L10 Nanophosphate, Clevertest Plus, All Pictograms, Single or Double Sided



| PRODUCT INFORMATION | |
|--------------------------------|--|
| Part Number | LUBPRO |
| MIC | UKA01310030003 |
| Description | Ultrablade Pro Exit, Recessed Ceiling Mount, L10 Nanophosphate, Clevertest Plus, All Pictograms, Single or Double Sided |
| Construction | PC/ABS body with PC Diffuser |
| Mounting | Recessed Ceiling |
| Dimensions L x W x H | 317mm x 157mm x 8.7mm (Blade Assembly) 385mm x 67mm (Cover Plate) |
| Cut-Out | 350mm x 48mm |
| Minimum Depth | 80mm |
| Weight | 1.1kg |
| Operating Mode | Maintained |
| Testing System | Clevertest Plus |
| Battery Type and Manufacturer | Lithium Nanophosphate (LiFePO4), Clevertronics |
| Charging Method | Intelligent current limited constant voltage |
| Diffuser | All directional inserts included in the box |
| Lamp(s) | 12 x LED, 100,000 hours |
| Operating Voltage | 240V AC; 50Hz |
| Supply Current | 0.038A |
| Power Factor | 0.446 |
| Power Consumption | 3.8W (Lamps ON Max), 1.6W (Lamps ON Standby) |
| Inrush Current (Peak/Duration) | 13.08A/84µs |
| Earth Leakage | 0.331mA |
| Viewing Distance | 30m |
| Rated Emergency Duration | 180 minutes |
| IP Rating | IP20 |
| Operating Temperature | 0°C to 40°C |
| Luminaire Classification | X 1 AFG 180 |
| Compliance Marking | 말 ((· |
| Appliance Class | Class II double insulated |
| Conformity | BS EN 60598-2-22, BS 5266 |

| REPLACEMENT PARTS | |
|-------------------|------------------|
| PART NUMBER | DESCRIPTION |
| 1533050 | Battery |
| UKM01370030003 | Emergency Driver |
| 8002178 | LED Panel |

The product details described in this document are current as at the version date of the document. We reserve the right to change product design, specifications or materials (Specifications) as part of our continuous improvement program. Please confirm the applicable Specifications at the time of placing your order.

