



RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-JUMBOEXIT
Date: 28 May 2021
We: Clevertronics Pty Ltd
1 Caribbean Drive
Scoresby VIC 3179 Australia
T: +61 3 9559 2700
E: Productenquiry@clevertronics.com.au
ABN: 64 136 264 349

Clevertronics Pty Ltd
Unit 22/761 Great South Road
Penrose, Auckland 1061, New Zealand
T: +64 800 548 448
E: Productenquiry@clevertronics.com.au
NZBN: 9429042377382

declare that CJELED-40-HV and the following associated product codes

CJELED-40-xx-yy-zz	LP Premium Jumbo Emergency Exit, 40m Viewing Distance
LJELED-40-xx-yy-zz	L10 Optimum Jumbo Emergency Exit, 40m Viewing Distance
CJELED-40-TH-uu-xx-ww-zz	LP Premium Jumbo Emergency Exit, Theatre Mask 40m Viewing Distance
LJELED-40-TH-uu-xx-ww-zz	L10 Optimum Jumbo Emergency Exit, Theatre Mask 40m Viewing Distance

Where,

uu = WM	Wall Mounted
uu = CM	Ceiling Mounted
ww = R	Running Man Decal
ww = RL	Left-Arrow Running-Man-Left Decal
ww = RR	Running-Man-Right Right-Arrow Decal
ww = DS-R	Double sided Running Man Decal
ww = DS-RAOW	Double sided Running Man Arrow One Way Decal
xx = Blank	Manual Test/Clevertest Plus (CTP)
xx = ZW	Zoneworks
xx = HV	Zoneworks XT HIVE
xx = DATA	Zoneworks DATA
xx = DALI	DALI Registered
yy = Blank	White Housing Colour
yy = BLK	Black Housing Colour
zz = Blank	Exit Sign with 2-hour emergency running time
zz = UPS	Exit Sign with Uninterruptible Power Supplies
zz = 4HR	Exit Sign with 4-hour emergency running time

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC).



RCM DECLARATION OF CONFORMITY

The above products meet requirements of the following standards:

AS/NZS 2293.3:2018

Emergency lighting and exit signs for buildings - Emergency luminaires and exit signs

AS 60598.2.22:2019

Luminaires – Part 2.22: Particular requirements – Luminaires for emergency Lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)

AS CISPR 15:2017

Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013+AMD1:2015 (ED.8.1) MOD)

Michael Duce

National Systems and Engineering
Manager

